

AC Optimal Power Flow Calculation for Locational Marginal Pricing

C. H. Monica Gokul* and K. Sarada

EEE Department, KL University, Vijayawada-522502, Andhra Pradesh, India; moni.sony1426@gmail.com, saradak@kluniversity.in

Abstract

This is the case of the ACOPF form, the blocking element of the Locational marginal price vector exhibit strong addiction on the power reference. In instruct to resolution this clash, a direct optimization outline is developed in this work this method is verified through an IEEE 30-bus scheme. **Method:** The power world simulator is used as a tool and in this an optimization technique is used to solve the both dc and AC optimal power flow. **Findings:** The marginal price details of each bus and linear programming solution is determined by comparing both AC and DC power flows. **Applications:** A power world simulator is used and for future scope a genetic algorithm, quadratic programming method can also be used.

Keywords: Congestion Value, Economic Transmission Right, Energy Location, Income Capability, Locational Marginal Price, Security Constrained Optimal Power Flow

1. Introduction

The electric service engineering has entered a novel epoch, one considered by contest among service-owned and sovereign authority, by long-time actions of power from one licence vicinity to another, and in some instance from one countryside to another, and by the growth of short-time market in which many consumer shop for the least price power for their clients. This better utilize of market forces, support of new dealers, rising confidence on financial system power deal and recent model in power corporation union has placed new load on the electric control transmission organization. Competent use of the transmission organization in a market situation label for modify in the association that preside over transmission dealings. "The generally dispute communal plan matter connecting the electric value production of the 1990s will likely be that of transmission right to use and the use of the bulk power system." One discontented obligation is for a reliable system

- short-time use pricing and

- long-time fixed transmission ability rights that can contain the difficult exertion of loop flow in the occurrence of line of thermal restrictions, bus voltage tolerances, and other constraints on the transmission organization.

1.1 Competent Utilize of the Electric Control Organization

The aim is to support financial competence in the usage of the electric power organization. financial transmit of electric power plants linked throughout a transmission network supply a normal starting aim for conversation of well-organized electricity marketplaces. beside description, financial send out make the most of the low remuneration prices subject to the ease of use of plants and the limitations of the transmission Locational Marginal Price (LMP) is defined as the minor price of supplying the next rise of electric power at a definite bus while considering the generation marginal cost and the physical aspects of the transmission system. According to the

*Author for correspondence

proposal of the U.S.FERC, an LMP-based marketplace worth come near is to direct the competent use of transmission organization when congestion occur on bulk power network. Consequently, such pricing can achieve short- and long-time competence in comprehensive electricity marketplaces. In some efficient markets, including the PJM interconnection, the New York market, and the New England market, ISO's are to affect the locational minor pricing^{2,3}. Under the SMD issued by FERC in July 2002, the ISO agree to the energy and value offers accepted by market members (e.g., vendors and consumers) and has the right and liability to arrange and decide on them support on a given purpose whereas preserve the system safety process. The ISO's goals may pick from a least cost formulation to the one those results in least amount probable change to original plan. The LMP disparity among two nearby buses is the congestion price which occur when the power is shifted from one position (insertion) to the other position (removal). Transmission fatalities may crash LMP distinctions since well. Minor fatalities correspond to additional change in organization fatalities due to additional command changes. Additional losses give up further costs which are referred to as the price of marginal fatalities such prices are included in the calculation of LMP. Accordingly, LMP is stated as given below i.e.

$$\text{LMP} = \text{LMP energy} + \text{LMP loss} + \text{LMP congestion}$$

That is, LMP is the summing up of the price of marginal energy, marginal loss, and congestion. Two common ways are useful for scheming LMP. One is to decide the three components individually and then add them up. A second way is to first analyse LMPs based on full ac system model and then recognize individual components as needed. The LMP distinctions between any two positions symbolize the price of transmission from the insertion to the removal, together with congestion and fatalities. When congestion is present in the transmission system, this technique first uses LF to determine the part of LMP that communicate to fatalities. Then, by subtracting the sum of the minor energy and the minor loss costs from the LMP at the position of interest, we can get the transmission congestion price.

2. DCOPF and ACOPF Formulation

The reform of the power built-up has posed a number of confronts in front of power organization engineers. Capable running of the complex congestion is one of the essential effective concerns under the rationalized

location. Evaluate to other approach of congestion administration, the LMP system has set up large approval right through the world remaining to its natural competence in the system facility distribution. The LMP method was first invented by Schweppes¹. Several LMP decomposition methods were later projected by other researchers⁴⁻¹². A theory of continuous LMP was projected in¹³. The ACOPF form is built upon the ACPF associations and, therefore, can precisely correspond to the power flow. But, two foremost deficiency of the ACOPF form are that

- It is too difficult oblige great execution time, and
- It may features the non-convergence problem.

The ACOPF form is at present employed in NYISO and CAISO. However, in most the marketplaces, the LMP computation is established out by using the DCOPF rough calculation. The DCOPF model is mainly used since of its ease, forcefulness and higher speed of meeting. For the DCOPF approach, the execution of locational minor pricing is straightforward if line fatalities are not included in the electricity cost computation¹⁴⁻¹⁶. However, due to the fact that the power loss in a large system may not be negligible, many markets are now moving towards minor loss pricing. As the dc power flow form, in itself, is lossless by description, it is necessary to expand an appropriate method to signify line fatalities within the DCOPF structure. To preserve convexity of the power transmit crisis, the line fatalities should be articulated as linear function of nodal insertion. The particular DCOPF model reveals energy orientation independency. However, if the slack load vector for the first form is chosen to be the same as the loss delivery vector for the second model, both the models will essentially produce the same solution for the transmit plan, line flows, LMPs and the congestion works of LMPs. This involve that both of these two models are essentially alike. The only distinction among them is that the position addition of the first copy is changed into loss allocation vector addition in the case of the second model. However, the virtual benefit of the second model is that there is no need to update loss coefficients and line flow compassion factors each time to improve the power flow accuracy. This is because the power flow accuracy for this form is exclusively presiding over by the collection of the loss allocation vector. In disparity, the power flow precision for the first model is preside over by the slack choice that also affects the ethics of loss Coefficients and line flow sensitivity feature. For both the DCOPF form^{17,18}

of the nodal loss coefficient vector is calculated by means of an ac power flow analysis on a base case system state. There is also an iterative move towards of minor loss pricing. For this move towards, a lossless DCOPF computation is initially carried out. Based upon the result of this lossless computation, an assessment of line losses is made. In the next and main iteration, the approximate loss in each line is dispersed as extra loads over its fatal nodes in a positive ratio. The loss factors are considered by means of a dc power flow analysis on the organization state obtained from the base iteration. The DCOPF form is, however, more accepted since it is simple and fast. Both the lossless and loss-compensated report of the DCOPF form Although the DCOPF form has the ability to provide a high level of power flow precision, it has several other margins. First of all, there is no definite rule to make a unique selection of the failure distribution plan. The problem is serious since the market glade resolution is highly prejudiced by the option of loss distribution. The next crisis is that one of the significant aspects of minor pricing, which declare that the market company should be banned from making effort to get a higher cost for the same amount, becomes partly lost because of the iterations involved in the DCOPF form training. Moreover, the DCOPF form is completely incompetent of taking into account the reactive power confines at dissimilar buses. In contrast to the DCOPF form, the ACOPF form is absolutely free from all the above problems. The ACOPF formulation is fairly straight forward and is based upon the accepted power flow description of the system. Therefore, there is no requiring to putting any further modelling effort to take into account the effect of system loss. The only problem connected with the ACOPF replica is that it is somewhat composite in nature, which sometimes makes its execution difficult. Although it is composite, the ACOPF form has already been effectively implement by CAISO. It is the point to spend extra investigate attempt to decide the problems concerned in the functioning of the ACOPF form so as to get the taste of its attracting description such as ideal compatibility with minor pricing, disagreement-free system modelling, and better ability to handle system limits.

For the ACOPF model, the transmit solutions and the Locational Marginal Prices (LMPs) are always sovereign of the choice of energy position if not some fake slack power(that cannot be set to zero) is distinct to model system safety. In dissimilarity, the congestion components of locational minor display tough confidence on the energy

position. Therefore, a specific argument arises concerning the position collection since the Financial Transmission Rights (FTRs) are estimated only according to the congestion components of locational marginal prices. The FTRs are essentially risk hedging instruments whose purpose is to provide price protector to the bold contracts against the LMP instability. The LMP decay is meant largely for the settlement of FTRs. a methodology was planned to decay the LMP vector irrespective of the selection of energy reference. However, equivalent to the particular LMP corrosion, there is no well-defined system for the revenue-adequate issuance of FTR.

3. Research Method

3.1 Design of LMP

Model 1:

The model based on data in Figure 1 demonstrates the idea of LMP. In this model, the purpose is the smallest sum price that clears a marketplace with fixed load. There are no generation confines on the two generating components. All lines have the similar reactance of 0.1 p.u. and fatalities are ignored. The following two cases are considered:

Case 1: LMP overlooking line flow limits

Case 2: LMP allowing for line flow limits

Case 3: In the unrestricted case, the cheaper unit G1 is transmitted alone to provide the load of 180MW and that it locates the cost at 10 \$/MWh. The entire cost is \$1800 (180MWh*10\$/MWh). In fact, the cost of providing a further load of 1MW at each bus have to be \$12 AND \$ 20 because the system is constrained, i.e.

$$\text{LMP1} + \text{LMP2} + \text{LMP3} = 10\$ /\text{MWh.} + 12\$/\text{MWh} + 20\$/\text{MWh}$$

The cost set by G1 is the MCP as shown in Figure 2.




Figure 1. The idea of LMP.

Case 4: Set the capability of line from 1 to 3 is 120MW and those of lines 2 and 3 to 60 MW. By viewing line flows in Case 1, we study that line 1 among buses 1 and 2 is constrained. Consequently, unit G1 supplies 120MW and the more high-priced unit G2 stores the residual load of 30 MW. The total cost is \$1560, i.e., $(120 \text{ MWh} * 10 \text{ \$/MWh}) + (30 \text{ MWh} * 12 \text{ \$/MWh})$. The unnatural flows in which LMPs develop into different. For example, if the command at bus 3 were to amplify by 1 MW, the further MW would not be totally complete by G1 since the unnatural line 1 prevents supplementary flow from bus 1 to bus 3. Therefore, weight at bus 3 will be complete by the extra costly unit G2 and equally G1 and G2 turn into minor units for providing the adding up load at bus 3. Such production setting up will give a dissimilar LMP at bus 3 (20\$/MWh) from the price of units in the organization.

In order to compute LMP3, $\Delta P1$ and $\Delta P2$ by units G1 and G2 correspondingly are necessary to provide the amplify in order at bus 3. Allowing for that all lines have the same reactance, 2/3 of $\Delta P1$ would flow on line 2 and 1/3 on line 1 and next line 3. By the same logic, 2/3 of $\Delta P2$ would flow on line 3 and 1/3 on line 1 and then line 2. Note that G2 can offset the flow among buses 1 and 2. In direct to keep the power run of line 1 at thermal edge; the extra flow on line 1 should be zero, i.e.

$$1/3 * \Delta P1 + 1/3 * \Delta P2 = 0.$$

In addition, for a 1 MW increase at bus 3, we have

$$\Delta P1 + \Delta P2 = 1 \text{ MW}.$$

This means that in order to keep the flow on line 1 within limits for financial transmit, 50% of additional stack at bus 3 is served by unit G1 and 50% by unit G2. So, LMP3 is




Figure 2. The cost set by G1 is the MCP.

$$\begin{aligned} \text{LMP3} &= (0.5 * 10 \text{ \$/MWh}) + (0.5 * 12 \text{ \$/MWh}) \\ &= 20 \text{ \$ / MWh} \end{aligned}$$

Similarly,

$$\text{LMP1} = 10 \text{ \$ /MWh} \text{ and } \text{LMP2} = 12 \text{ \$ /MWh}.$$

4. Illustrative Method

The IEEE 30– bus system is taken in an optimal state its block diagram is as shown in Figure 3 and its generator and cost details are given in Table 1.

5. Results

As the same LMP formulation is obtained in IEEE 30 bus system the results are obtained by using power world simulator as shown in Table 2 and Table 3.

Table 1. Generator cost details

Gen no.	Pi min	Pi max	Qi min	Qi Max	A (\$/MWh ²)	B (\$/MWh)	c
1	50	200	-	-	0.00375	2.00	0
2	20	80	-20	100	0.01750	1.75	0
5	15	50	-15	80	0.06250	1.00	0
8	10	35	-15	60	0.00834	3.25	0
11	10	30	-10	50	0.02500	3.00	0
13	12	40	-15	60	0.02500	3.00	0




Figure 3. IEEE 30 Bus system.

Table 2. LP solution details

Sl.no	Non basic variables	Cost (low)	Cost (up)	Down range	UP range	Reduced cost up	Reduced cost down	Break points
1	0	3.37	3.37	16.15	13.8	0	0	N
2	5	2.98	4.03	30.00	30.0	0.2	0.824	Y
3	4	At min	3.97	17.50	17.5	0.15	–	Y
4	2	3.73	At max	At max	At max	–	0.330	Y
5	0	3.75	3.75	8	8	0	0	N
6	6	At min	3.95	14	14	–	–	Y
7	1	At min	At max	At max	At max	0.23		Y
8	3	At min	0	13	13	0.48		Y

Table 3. Marginal price details

Bus no.	MW Marginal cost	Congestion cost
1	3.37	0.00
2	3.80	0.44
3	3.62	0.26
4	3.68	0.31
5	3.81	0.44
6	3.76	0.39
7	3.79	0.42
8	3.76	0.39
9	3.75	0.38
10	3.74	0.37
11	3.75	0.38
12	3.71	0.34
13	3.71	0.34
14	3.72	0.35
15	3.73	0.36
16	3.73	0.37
17	3.74	0.37
18	3.74	0.37
19	3.74	0.37
20	3.74	0.38
21	3.75	0.38
22	3.74	0.37
23	3.74	0.38
24	3.75	0.38
25	3.75	0.39
26	3.76	0.38
27	3.75	0.38
28	3.76	0.40
29	3.77	0.40
30	3.77	0.40

6. Conclusion

An optimization-based technique is projected in this document to decide the energy location disagreement for the ACOPF-based locational minor pricing. The individual argument occurs since of the position reliant life of the congestion mechanism of locational marginal prices. To contract with this matter, the interrelationship between the congestion components of spot prices is originally recognized. Consequently, an appropriate purpose utility is defined for the most potential improvement of the risk-hedging potential of FTRs. The essential constraining factors are then recognized so as to make sure a correct functioning of the FTR mechanism. In all, the exacting optimization structure is designed with complete focal point on the proper intention of LMP corrosion. The optimization crisis that is eventually to be solved is a simple quadratic programming crisis with only one uneven and two limits. The instant explanation that is acquire by solving the over optimization problem is the LMP congestion constituent at the angle location bus. Consequently, the congestion components at other buses can be resolute by employing the interrelationship exposed. It is also exposed from this effort that there is no way to make sure the income adequacy of FTRs (Financial Transmission Rates) in move forwards in the case of ACOPF-based marginal loss pricing.

7. References

1. Schweppe FC, Caramanis MC, Tabors RD, Bohn RE. Spot Pricing of Electricity. Norwell, MA: Kluwer; 1988.
2. Shahidehpour M, Yamin H, Li ZY. Market operations in electric power system. New York: John Wiley and Sons, Inc; 2002.

3. Li Z, Daneshi H. Some observations on market clearing price and locational marginal price. IEEE Power Engineering Society General Meeting; 2005 Jun. p. 2702–9.
4. Chen L, Suzuki H, Wachi T, Shimura Y. Components of nodal prices for electric power systems. IEEE Trans Power Syst. 2002 Feb; 17(1):41–9.
5. Finney JD, Othman HA, Rutz WL. Evaluating transmission congestion constraints in system planning. IEEE Trans Power Syst. 1997 Aug; 12(3):1143–50.
6. Wu T, Alaywan Z, Papalexopoulos AD. Locational marginal price calculations using the distributed-slack power-flow formulation. IEEE Trans Power Syst. 2005 May; 20(2):1188–90.
7. Cheng X, Overbye TJ. An energy reference bus independent LMP decomposition algorithm. IEEE Trans Power Syst. 2006 Aug; 21(3):1041–9.
8. Orfanogianni T, Gross G. A general formulation for LMP evaluation. IEEE Trans Power Syst. 2007 Aug; 22(3):1163–73.
9. Wang L, Mazumdar M. Using a system model to decompose the effects of influential factors on locational marginal prices. IEEE Trans Power Syst. 2007 Nov; 22(4):1456–65.
10. Litvinov E, Zheng T, Rosenwald G, Shamsollahi P. Marginal loss modelling in LMP calculation. IEEE Trans Power Syst. 2004 May; 19(2):880–8.
11. Fu Y, Li Z. Different models and properties on LMP calculations. Proceedings of IEEE/Power Eng Society, General Meeting; 2006 Jun; p. 18–22.
12. Li F, Bo R. DCOPF-based LMP simulation: Algorithm, comparison with ACOPF, and sensitivity. IEEE Trans Power Syst. 2007 Nov; 22(4):1475–85.
13. Li F. Continuous locational marginal pricing (CLMP). IEEE Trans Power Syst. 2007 Nov; 22(4):1638–46.
14. Liu M, Gross G. Framework for the design and analysis of congestion revenue rights. IEEE Trans Power Syst. 2004 Feb; 19(1):243–51.
15. Li Z, Daneshi H. Some observations on market clearing price and locational marginal price. Proceedings of IEEE/Power Eng Society, General Meeting; 2005 Jun 12–16; 2:2042–9.
16. Sheathe GB, Forsake PAJ. Congestion-driven transmission expansion in competitive power markets. IEEE Trans Power Syst. 2004 Aug; 19(3):1658–65.
17. Litvinov E, Zheng T, Rosenwald G, Shamsollahi P. Marginal loss modelling in LMP calculation. IEEE Trans Power Syst. 2004 May; 19(2):880–8.
18. Fu Y, Li Z. Different models and properties on LMP calculations. Proceedings of IEEE/Power Eng Society General Meeting 2006 June 8–22.

Appendix

LMP- Locational marginal pricing

FERC-Federal energy regulatory commission

ISO- International system of organization

SMD-Standard market design

FTR'S-Financial transmission rates

ACPF-Ac power flow

DCPF-Dc power flow

NYISO-New York international system organization

CAISO- California independent system operator